

RAMCROil - INSTRUMENTATION Cable

For standard applications, flame retardant.

Multi-Core, HT 105°-Insulation, Collective Screen, PVC-Sheath

SAS0603HEACX-T-UL13

Application

These cables are designed to connect electronic instrumentation, analog and digital signal circuits. This cable does not spread flame to the top of the tray in the Vertical-Tray Flame Test in UL 1685.

Construction

		Unit	Nominal Value
Formation	6 Cores		
Section	16AWG		
Conductor	tinned copper wire, 7 strand	mm	1,5
Insulation	Hi Temperature polyvinyl chloride - PVC HT 105°C	mm	2,3
Colour Code	0		
Individual Screen	N.A.		
Wrapping	at least 1 layer of plastic tape 0,023 mm		
Collective Screen	0,026 mm Aluminium / PETP tape over tinned copper drain wire		
Inner Sheath	N.A.		
Armour	N.A.		
Outer Sheath	polyvinyl chloride - PVC - Black	mm	9,0
Cable Printing	RAMCRO S.p.A. - (UL) Listed E345186 Type PLTC - 6C 16AWG Shielded - 105°C + BATCH + METER MARKING		

Technical Data & Standard References

Fire Propagation:		Construction Reference Standard:	UL 13
- Test on single cable	IEC 60332-1	Type of Cable:	PLTC Cable
- Test on bunched cables	IEC 60332-3		
- Vertical Tray Flame Test	UL1685	Other References:	
Limiting Oxygen Index (LOI)	ASTM D 2863 (min 30%)	- NEC code, sec. 725 PLTC,	
Flammability temperature (FT)		- NEC code, sec. 727 ITC,	
Amount of halogen acid gas	IEC 60754-1 (max 15%)	- UL 1685	
Sunlight resistance	UL 1581 section 1200	- ASTM D 1239	
Notes		- NF C 32-020	
0		- IRAM IAP	
		- IEC 79-14	

Electrical & Mechanical Data

Conductor Cross-section	Nom.	16AWG	Temperature Range:	
DC Resistance per core at 20° C	max Ω/km	14,2	During Operation	° C -30° C up to +105°C
Insulation Resistance at 20° C	min Ω*km	25	During Installation	° C -5° C up to +50°C
Mutual Capacitance	max nF/km	140		
Inductance	max mH/km	1	Min. Bending Radius	mm 6 x cable diameter
Test Voltage - Core/Core	V	2000	Max Pulling Tension	N/mm2 389
Test Voltage - Core/Screen	V	2000	Weight Approx	kg/km 161
L/R Ratio	max μH/Ω	25		
Operating Voltage	V	300		

Issued by: sabrina



Date of issue:

Prepared by RAMCRO Tech Via Marzorati, 15 - 20014 Nerviano - Milan - Italy / www.ramcro.it

21/07/2014 00:00

Creator: LDG

Transfer to third parties only under authorization by Ramcro S.p.A.

Form 1

Printing errors excepted. Subject to alterations.